

VOICE MAIL RFP 06-060 AAB
SUBMITTED QUESTIONS AND ANSWERS 6/30/2006

Q#	Section and Page #	Question	Answer
1.	Section C, General Question	What type of flooring the UPS for the new voice messaging system will be installed on?	The floor is post-tension concrete. This means it must be x-rayed before any drilling is done. .